

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 8534-0995:100 Page 1 of 1

CATEGORY: Nonmetallic Ducts

LISTEE: ATCO Rubber Products, 710 Atco Drive., Ft. Worth TX 76118
Contact: M.A. Koerber (864) 261-8540 Fax (864) 261-8617*

DESIGN: ARP series Types I, IV, V, VI and VII non metallic ducts. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, type of joining system, maximum air velocity, maximum positive/negative static air pressure and UL label.

APPROVAL: Listed as nonmetallic ducts. Types I, IV, V and VII rated as Class I; Type VI rated as Class 0. Authority having jurisdiction should be consulted prior to installation.

*Rev. 06-20-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 21, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager